

## CORRIGENDUM AGAINST NIT CLAUSES

Sl. No.	NIT Clause No.	Details as per ORIGINAL NIT	Amendments
1	11 (Pg-14) of General Terms & Conditions of Contract	<p style="text-align: center;"><b>COMPLETION PERIOD</b></p> <p><b>Delivery</b> of materials to be completed within <b>10-12 weeks</b> from the date of Purchase Order. Installation and commissioning to be completed in another 2-4 weeks.</p>	<p><b>Delivery of Materials : 24-26 weeks time.</b></p> <p>Execution(Installation &amp; Commissioning) time of 2-4 weeks shall remain unchanged</p>
2	Page-37 & 38 of NIT under "Technical Specification" clause	<p>1. <b>CBCB</b> approved DG Set.(Pg-37).</p> <p>2. Acoustic enclosure as per CPCB norms(Pg-38).</p>	DG Model to be supplied shall be <b>CPCB</b> approved one.
3	Page-8 under clause, "Scope of Work"	Obtaining clearance from statutory Agencies, Government Departments etc wherever necessary.	Local PCB Approval to be obtained by successful vendor.
4	NA	There was no mention about this in NIT.	LT Panel Room construction & its illumination to be done by Balmer Lawrie
5	Page-8 under clause, "Scope of Work"	Obtaining clearance from statutory Agencies, Government Departments etc wherever necessary.	DG Duty approval from State Govt. Authority to be obtained by successful vendor.
6	NA	There was no mention about this in NIT.	In DG enclosure AMF Panel provision and connection is must.
7	Page-47, in Bidder Particulars	GST Registration doc was asked from vendor.	GST Registration in West Bengal is mandatory.
8	Page-8 under clause, "Scope of Work"	All associated civil works for the foundation of the equipments shall be under the scope of the bidder. The bidder shall provide price of all Electrical & Civil works separately as per the format given in the BOQ (Price Bid) described in this tender document later.	All allied & associated works and accessories should be envisaged by bidder and quote accordingly for BOQ items

Sl. No.	NIT Clause No.	Details as per ORIGINAL NIT	Amendments
9		APPROVED BRANDS	
	Page-28 of NIT under "Technical Specification" clause	<b>Transformer</b> : CGL, Siemens, Sudhir & Schneider	Kirloskar, CGL, Voltamp, Siemens, Sudhir & Schneider
	Page-19 of NIT under "Technical Specification" clause	<b>HT Breaker</b> : Schneider, Siemens, Biecco, CGL.	Schneider, Siemens, Biecco, C & S, ABB.
	Page-37 of NIT under "Technical Specification" clause	<b>DG Set</b> : Kirloskar, Jakson, Greaves Cotton, & Cummins.	Jakson, Greaves Cotton, Kirloskar, Perkins & Cummins.
	Page-33 of NIT under "Technical Specification" clause	<b>LT Panel</b> : Schneider, L&T, C&S, Siemens or their authorized panel fabricators	Schneider, L & T, C & S, Siemens or their authorized system house.
	Page-39 of NIT under "Technical Specification" clause	<b>Cables</b> : Havells, Polycab, RPG, Gloster and Universal or equivalent.	Havells, Polycab, Finolex, Asian(RPG), Gloster and Universal