

BLCL/IPC/18-19 dt. 14.06.2018

CORRIGENDUM to TENDER

Please note “Response from Registered Vendors alone will be accepted” for participation in this Limited Tender / CORRIGENDUM.

In case your firm is already Registered & Approved Vendor of Industrial Packaging (or) other units of M/s. Balmer Lawrie & Co. Ltd., elsewhere in India, the details of the same to be provided prior to participating in this tender.

Other vendors may contact the undersigned for registering with the unit which is subject to confirmation by our company. Only after confirmation of their registration, they would be considered for participation in the subsequent tenders. ”

Dear Sirs,

Sub: Specification Modified - Tender for Supply & Commissioning of 10KVA UPS with suitable Battery.

Ref. Limited Tender 1070LC0191 dt.08.06.2018.

This has reference to above cited tender sent to you for our subject requirement.

The following **changes are being made under** of the above referred tender.

SNo. Description of Material & Qty. Original as in Tender	Changes under this CORRIGENDUM
<u>Original Specification :</u> 3. UPS supply shall include 20 Numbers of 12V-40 AH SMF Battery (fully charged), Metal Rack to house the Battery and Interlink and DC Cables (Minimum 14400 VAH is required).	<u>Revised Specification :</u> 3. UPS supply shall include 20 Numbers of ** 12V-42Ah SMF Battery (fully charged), Metal Rack to house the Batteries and Interlink and DC Cables.

The bidders are requested **to note the above change** and accordingly submit their bids.**

Bidders who have already submitted their bids shall re-submit their bids incorporating the above changes.

“All other information given in the above Tender remains unchanged”.

Bidders are requested to forward their bid **on or before 20.06.18 @ 3.00pm** incorporating the above revised specification.

Yours faithfully

For Balmer Lawrie & Co. Ltd.

(T.S. Elangovan)

Executive (Purchase)

☎-044-2594 6651 ✉ - elangovan.ts@balmerlawrie.com