

**Balmer Lawrie & Co. Ltd.**  
**Engineering & Projects**

**Corrigendum No:1 , Corrigendum Date: 13.09.2019**

1. Arrangement shown in tender drawing no. EP/TCW/BHU/02, SHEET 1 OF 2 Rev. 00 "STRUCTURAL PLAN AT RAFTER LEVEL" is changed between grid 9 & grid 10. Instead of supporting 4 nos 1.5T ACU's, the "ACU SUPPORTING BEAMS (04 SETS)", now need to support 8 nos. 1.5T ACU's. Accordingly, beam arrangement has been modified.
2. Refer to the revised drawing no. EP/TCW/BHU/02 SHEET 1 OF 2 Rev. 01, as uploaded.
3. Similar load from ACU for 8nos frozen chambers between grids 3' to 7 shall be considered as per the drawing.
4. There will be pre-bid meeting on 20.09.19 at 11AM in Kolkata. Please refer clause no. 16 of NIT for details.
5. Bidder shall require to submit this corrigendum duly stamped & signed alongwith the hard copy submission within the due date.

